

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **SCHÖNOX HPS NORTH AMERICA, INC.**
511 Wilhite Street, Florence, AL 35630

Category: Construction Materials - Concrete Flooring Products
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less (classroom)*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *0.5 - 5.0 mg/m³ (private office)*
adhesives & sealants

Certified Products: SMP - Silane Modified Polymer Products: Protect**.

** Product tested as representative exemplar of products listed above.

Test Date: August 09, 2024 Report No.:2400493 Certificate No.: MAS2400493-07

Valid: August 2024 to August 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>